



„Spamel“



Przyłączenie zasilania do wtyczki tabl. 16A/3P+N+PE.  
Odbiornik podłączyć do zacisków 2T1 4T2 6T3 PE.



Technical drawing of a square base plate. The overall width is  $148 \pm 5$  mm and the overall height is  $175 \pm 5$  mm. The inner square area has a width of  $95 \pm 5$  mm and a height of  $120 \pm 5$  mm. There are four mounting holes, each with a diameter of  $\varnothing 6$  mm, located at the corners of the inner square. The distance between the centers of the holes is  $95 \pm 5$  mm. The drawing also shows a central triangular feature with a height of 1 mm. The text 'GNIAZDA NA OTWORY DO MOCOWANIA ZESTAWU  $\varnothing 6$  lub  $\varnothing 14$ ' is present at the top.

1. MONTAŻ I DEMONTAŻ POWINNA WYKONYWAĆ OSOBA POSIADAJĄCA UPRAWNIENIA ELEKTRYCZNE;
2. PRODUCENT NIE PONOSI ODPOWIEDZIALNOŚCI ZA SKUTKI INSTALACJI I EKSPLOATACJI ZESTAWU RZ NIEZGODNIE Z INSTRUKCJĄ I PRZEZNACZENIEM;
3. DO PODŁĄCZANIA STOSOWAĆ PRZEWODY Z KOŃCÓWKAMI TYPU TKL;
4. ZESTAWY RZ NALEŻY INSTALOWAĆ NA PODŁOŻACH TRUDNOPALNYCH;
5. GRUPA MATERIAŁOWA III;
6. STOPIEŃ ZANIECZYSZCZENIA 2.