# Cam switch in enclosure ŁK63 OB4



OB4









OB4Z

## **Ordering code**

ŁK 63 -


OB4 in housing OB4 OB4C in housing OB4 with yellow-red front
OB4Z in housing OB4 with lockable front
OB4ZC in housing OB4 with lockable yellow-red front


Mounting


	Assembly number
1.825 1.828 2.8211 2.8210 3.8220 3.8210 3.8368 3.83139	Disconnector 0-1 (1 - pole) Disconnector 0-1 (2 - pole) Disconnector 0-1 (3 - pole) Disconnector 0-1 (4 - pole) Disconnector 0-1 (5 - pole) Disconnector 0-1 (6 - pole) Reversing switch L-0-P 2-speed switch 2 separate windings
2.4414 2.8445 1.834 2.8338 3.8380	Rotary disconnector 0-1 Control switch 0-1-2-3 Disconnector 1-0-2 (1 - pol Disconnector 1-0-2 (2 - pol Disconnector 1-0-2 (3 - pol


Current 63 63 A

# **Dimensions**









## Number of segments in the switch

1 ... 3

## **Gland type**

M32×1,5

Note!

For assembly ŁK63-3.8368 3 glands M25×1,5 are used

Technical data (continuous work)	
Rated insulation voltage U <sub>i</sub>	690 V
Rated with stand impulse voltage $U_{\rm imp}$	6 kV
Rated continuous current I <sub>u</sub> =I <sub>th</sub>	63 A
Rated operational power P <sub>e</sub> for AC-3	20 kW (400 V) 20 kW (500 V) 10 kW (690 V)
Rated operational power P <sub>e</sub> for AC-4	12 kW (400 V) 8 kW (690 V)
Rated operational current I <sub>e</sub> for AC-3	38 A (400 V) 30 A (500 V) 11 A (690 V)
Rated operational current I <sub>e</sub> for AC-4	23 A (400 V) 8.5 A (690 V)
Short-time short-circuit withstand current I <sub>cw</sub> (1s)	1.2 kA
Rated short-circuit making current I <sub>cm</sub>	2.2 kA
Tightening torque, terminals	2.0 Nm
Mechanical endurance	3.0 mln (transposition cycles)
Ambient temperature	-40 +70°C (work) -40 +70°C (storage)
Wire gauge	410 mm <sup>2</sup>
Protection level: PN-EN 60529 to the panel	IP41 IP65
Vibration test (acc. to IEC 60068-2-6)	213, 2100 Hz (frequency) $\pm$ 1 mm (acceleration amplitude) $\pm$ 0.7 g (acceleration amplitude)
Shock test (acc. to IEC 60068-2-27)	15 g (peak acceleration) 11 ms (impulse duration)
Damp heat cyclic test (acc. to IEC 60068-2-30)	55°C (ambient temperature) 95% (relative humidity)
Salt mist cyclic test (acc. to IEC 60068-2-52)	severity 1