



Ordering code

OA1-	[]	-	[]	.	G\	[]	[]	[]
								Hammer without hammer -M with hammer
								Signalling without signalling -24 with signalling LED 24V AC/DC -230 with signalling LED 230V AC
								Switches 10, 20, 30 01, 02, 03 11, 12 21
								Pushbutton type A triggered automatically after breaking the glass B after breaking the glass press the button manually
								Version W01 surface mounting W02 flush

Code examples:

code examples:
OA1-W01-A.G-02-24

On-plaster mounting, 2 NC switches. When the glass is broken the pushbutton is released automatically, type A. Signalling LED 24 V DC.

OA1-W02-B.G-10-230-M

Flush mounting with 1 NO switch. When the glass is broken it is necessary to push the button, type B.
Signalling LED 230 V AC. With a hammer.

Product description

Manual pushbutton OA1 is intended for applications where emergency manual control is required.

For example, emergency passages which must be opened after breaking the glass element. OA1 is also intended for applications where in an emergency the power supply must be cut off after breaking the glass element.

OA1 is available in two versions, type A and B. In type A, the switch is released after breaking the glass in an emergency. In type B, after breaking the glass the momentary pushbutton must be pressed. OA1 is available in flush and surface mounted assemblies. Each enclosure can be fitted with up to three switches SP22-10 (NO) or SP22-01 (NC).

The signal is triggered and sent after breaking the glass (type A) or after breaking the glass and pressing the momentary pushbutton (type B). The alarm signal is reset after replacing the breakable element (glass - ordering code PPOŽ-5701).

Note

When selecting current paths, the selected type (A or B) should be taken into account

TYP A

NO contacts (10, 20, 30): after breaking the glass or removing the cover, the contacts open.

NC contacts (01, 02, 03): after breaking the glass or removing the cover, the contacts close.

Mixed NC/NO contacts (11, 12, 21): after breaking the glass, the NO contacts will open and the NC contacts will close.

TYP B

NO contacts (10, 20, 30): after breaking the glass or removing the cover, the button must be pressed manually - the contacts will close.

NC contacts (01, 02, 03): after breaking the glass or removing the cover, the button must be pressed manually - the contacts will open.


Mixed NC/NO contacts (11, 12, 21): after pressing the button, the NO contacts will close and the NC contacts will open.

Technical data

Rated insulation voltage U_i	500 V
Rated continuous current $I_u=I_{th}$	10 A
Rated operational current I_e for AC-15	2.5 A (230 V) 1.6 A (400/500 V)
Rated operational current I_e for AC-13	4 A (24 V) 1 A (110 V) 0.25 A (220 V)
Degree of protection	IP65
Wire gauge	2× 1...2.5 mm ² (solid) 2× 1...2.5 mm ² (stranded)

Dimensions

surface mounting



flush mounting

